



NOTES

ALL EMBEDS ARE ± 3" U.O.N.

I.D. DETAILS = MANUFACTURER, CUSTOMER, WT, DATE MFG, POLE TYPE, LENGTH & QPL #

POLE MUST BE PICKED UP AND STORED AT TWO POINTS, APPROX. 3'-8" FT. FROM TOP AND 3-8" FT. FROM BUTT. CAUTION: LIFTING THIS POLE WITH A SINGLE POINT PICK-UP WILL RESULT IN DAMAGE TO THE POLE.

THIS POLE SHALL MEET OR EXCEED REQUIREMENTS SET FORTH BY F.D.O.T. SPECIFICATIONS.

POLE ELEVATION
N.T.S.

MATERIALS SPECIFICATION

- F'C = 6,000 PSI (28 DAYS)
- F'CI = 4,000 PSI (RELEASE)
- Fu = 270 KSI FOR PRESTRESSING STRANDS COMPLYING WITH ASTM A416
- FY = 60 KSI FOR STIRRUPS AND REINFORCING BARS PER ASTM A615
- FY = 60 KSI SPIRAL WIRE PER ASTM A82

STATE PROJECT # _____

TYPE P-VI (STRAIN POLE)

DS JOB NO:	DATE:	RELEASED:
CHK'D:	APPR:	
DRAWN:		
JOB NAME:	LOCATION:	
ARCHITECT:	ENGINEER:	
CONTRACTOR:	PROJ. NO:	



DURA-STRESS Inc.
P.O. BOX 490779 LEESBURG, FL 34749-0779
PHONE (352) 787-1422 FAX. (352) 787-0080

STRUCTURAL PRESTRESSED AND ARCHITECTURAL PRECAST CONCRETE PRODUCTS

REV	DESCRIPTION	DATE	BY	CHK.

